



PUBLIC NOTICE

Notice #: 13446-3 Permit #: 13446

Date: December 12, 2016

This notice is to inform the public that the S.C. Department of Health and Environmental Control (DHEC) is taking comments on a Corrective Action Plan (CAP). The CAP addresses remediation of soil and groundwater contamination at the facility listed below. The contamination was caused by a petroleum release from the underground storage tank (UST) system at this location.

FACILITY: AOC I (STO-13), Base Gasoline Station Leak, Joint Base Charleston- Air, SC

APPLICANT: FPM Remediations, Inc., 181 Kenwood Avenue, Oneida, NY on behalf of the Air Force Civil Engineer Center (AFCEC) and Joint Base Charleston- Air

SUMMARY OF CAP: Petroleum compounds naturally degrade over time through chemical, physical, and biological processes. These processes are called natural attenuation. FPM has submitted a CAP proposing the use of natural attenuation in addition to the following technologies to remediate up the petroleum contamination:

- Excavation: Removal of shallow petroleum-contaminated soils
- Chemical injection: Subsurface application of oxygen-releasing compound by temporary wells (direct-push) and by horizontal wells (injection galleries) to oxidize petroleum contaminants and enhance biodegradation by naturally-occurring bacteria.

PUBLIC COMMENT PERIOD DEADLINE: The deadline for submitting written comments is January 12, 2017. Any interested person(s) may submit written comments concerning the remediation to the Project Manager listed below. Please bring this notice to the attention of persons whom you know will be interested in this matter. Where there is a significant degree of public interest, DHEC will hold a public hearing.

Joel P. Padgett, P.G.
SCDHEC- UST Management Division
2600 Bull Street
Columbia SC 29201
803-898-0655

CONTACT INFORMATION: For additional information, please call the Project Manager listed above. To view a copy of the CAP, contact the DHEC Freedom of Information Office at 803-898-3880.

Section 280.67 of the S.C. Underground Storage Tank Control Regulations (R.61-92) requires that any CAP prepared to meet the requirements of 280.66 be placed on notice for public comment.